

Water System Name and PWS ID#	NORTH PLAINS WATER DEPARTMENT, 41-00576
System Size	Large System, 300+ connections
Date Report was Received	02/22/21 1:40 PM
ASR Contact	Blake Boyles
Email Address	blake.boyles@northplains.org
Contact Phone Number	503-389-1397
Residential Connection	1325
High Hazard Connection	0
Other Connections	28
Total Connections	1353
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Blake Boyles
Specialist Cert #	2208
WS Employee/Contracted	Water System Employee, or
Phone #	503-389-1397
Email Address	blake.boyles@northplains.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 18</p> <p>Tested 3</p> <p>Passed 3</p> <p>Failed 0</p> <p>% of RPs tested 17%</p> <p>Comments Due to COVID over 90% of businesses were closed some will not reopen.</p>
<p>Do you have any DCs? Yes</p> <p>How many 521</p> <p>Tested 85</p> <p>Passed 85</p> <p>Failed 0</p> <p>% of DCs tested 16%</p> <p>Comments Due to 2020 Covid19 many residents were unemployed during the summer months and had agreed to abstain from using their irrigation to limit the monthly water bill. Thus we allowed the devices to not be tested this year, but will be tested in 2021 when employment resumed and irrigation would be used.</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system