

Water System Name and PWS ID#	OCEANSIDE WATER DISTRICT, 41-00585
System Size	Large System, 300+ connections
Date Report was Received	03/18/21 11:07 AM
ASR Contact	Julie Johnson
Email Address	oceansidewaterdistrict@gmail.com
Contact Phone Number	503-842-0370
Residential Connection	563.00
High Hazard Connection	3
Other Connections	5
Total Connections	571
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Justin Hartford
Specialist Cert #	702150
WS Employee/Contracted	Water System Employee, or
Phone #	503-812-2279
Email Address	osidewaterjustin@gmail.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 8</p> <p>Tested 8</p> <p>Passed 8</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 22</p> <p>Tested 22</p> <p>Passed 22</p> <p>Failed 0</p> <p>% of DCs tested 100%</p> <p>Comments Please disregard the prior report submitted, this has the correct information.</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system