

2018 Annual Summary Report (ASR)

Row 235

Primary

Entered

Data Online

Water System Name ONTARIO, CITY OF, 41-00587

ASR Contact Casey Mordhorst

Email Address casey.mordhorst@jacobs.com

Contact Phone Number 541-889-8572

Residential Connections 3117

High Hazard Connections 36

Other Connections 545

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Al Haun

CCCS Information Water System Employee, or

CCCS Cert # 5200

CCCS Phone 541-889-8572

CCCS Email Al.haun@jacobs.com

Current written backflow prevention program plan? Yes

| | |
|------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BFPP - list of high hazards | Yes |
| BFPP - Procedure | Yes |
| BFPP Notify Water User | Yes |
| BFPP - Type of Protection | Yes |
| BFPP - Corrective Action | Yes |
| BFPP - Current records | Yes |
| BFPP - Public Education | Yes |
| Do you have RP? | Yes |
| RP - How Many | 295 |
| RP - Tested | 307 |
| RP - Passed | 290 |
| RP - Failed | 13 |
| % Tested | |
| RP - Comments | |
| Do you have any DC? | Yes |
| DC - How Many | 1299 |
| DC - Tested | 1291 |
| DC - Passed | 1254 |
| DC - Failed | 22 |
| DC - Comments | Due to the irrigation water being shut off before some of the devices had their annual test done. The devices that were not tested we will require a test before their irrigation water will be turned on this spring |
| Do you have any PVBs? | Yes |
| PVB - How | 334 |

Many

PVB - Tested 346

PVB - Passed 320

PVB - Failed 14

PVB - Comments Due to the irrigation water being shut off before some of the devices had their annual test done. The devices that were not tested we will require a test before their irrigation water will be turned on this spring

I certify

Column47
