

## KELLER Molly A

---

**From:** Molly Keller via Smartsheet <user@smartsheet.com>  
**Sent:** Thursday, March 12, 2020 1:35 PM  
**To:** Molly Keller  
**Subject:** OTTER ROCK WATER DISTRICT, 41-00608

**Think twice** before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



OTTER ROCK WATER DISTRICT, 41-00608

# 2019 Annual Summary Report (ASR)

Row 6

**Created** 03/11/20 12:26 PM

**Entered**

**Data Online**

**Water System Name** OTTER ROCK WATER DISTRICT, 41-00608

**ASR Contact** James Osburn

**Email Address** orwdsuper@gmail.com

**Contact Phone Number** 503-536-3578

**Residential Connections** 139

**High Hazard Connections** 1

**Other Connections**

**Enabling Authority** Yes

**Revised  
Enabling  
Authority**            No

---

**CCCS Name -  
Large system  
only**            na

---

**CCCS  
Information -  
Large system  
only**

---

**CCCS Cert # -  
Large system  
only**

---

**CCCS Phone -  
Large system  
only**

---

**CCCS Email -  
Large system  
only**

---

**Written BFP  
program plan?  
- Large system  
only**

---

**BFPP - list of  
high hazards -  
Large system  
only**

---

**BFPP -  
Procedure -  
Large system  
only**

---

**BFPP Notify  
Water User -  
Large system  
only**

---

**BFPP - Type of  
Protection -  
Large system  
only**

---

**BFPP -  
Corrective  
Action - Large  
system only**

**BFPP - Current records - Large system only**

**BFPP - Public Education - Large system only**

**Do you have RP?** No

**RP - How Many** 1

**RP - Tested** 0

**RP - Passed** 0

**RP - Failed** 0

**RP % Tested** 0%

**RP - Comments** The RP is installed in a seasonal restaurant in Otter Rock. The annual test was done in the past during the off season for the restaurant. The previous company contracted to annually test the backflow assembly, however, the owner had retired, and somehow it was skipped. A new company has been contracted to annually test the device and it has been done this year, however, last year (2019) no test was completed.

**Do you have any DC?** No

**DC - How Many** 0

**DC - Tested** 0

**DC - Passed** 0

**DC - Failed** 0

**DC - % Tested**

**DC - Comments**

**Do you have any PVBs?** No

**PVB - How Many** 0

**PVB - Tested** 0

**PVB - Passed** 0

**PVB - Failed**    0

---

**PVB - % Tested**

---

**PVB -  
Comments**

---

**I certify**   

---

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by [molly.a.keller@state.or.us](mailto:molly.a.keller@state.or.us)

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)