

2018 Annual Summary Report (ASR)

Row 242

Primary

Entered

Data Online

Water System Name PACIFIC CITY JOINT WATER - SAN AUTH, 41-00609

ASR Contact Tony Owen

Email Address towen@pcjwsa.com

Contact Phone Number 503-965-6636

Residential Connections 1321

High Hazard Connections 12

Other Connections 76

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Tony Owen

CCCS Information Water System Employee, or

CCCS Cert # 3548

CCCS Phone 503-965-6636

CCCS Email towen@pcjwsa.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	56
RP - Tested	76
RP - Passed	74
RP - Failed	2
% Tested	136%
RP - Comments	20 RPs tested in December 2018 due in January 2019. 1 failure is being removed. 1 failure is under enforcement activities.
Do you have any DC?	Yes
DC - How Many	154
DC - Tested	146
DC - Passed	145
DC - Failed	1
DC - Comments	8 DCs due in December 2018 were tested in January 2019. 1 failure is under enforcement activities.
Do you have any PVBs?	No
PVB - How	

Many

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
