

Water System Name and PWS ID#	PACIFIC CITY JOINT WATER - SAN AUTH, 41-00609
System Size	Large System, 300+ connections
Date Report was Received	03/23/21 1:40 PM
ASR Contact	Rachelle DeLoe
Email Address	rdeloe@pcjwsa.com
Contact Phone Number	503-965-6636
Residential Connection	1,374.00
High Hazard Connection	12
Other Connections	76
Total Connections	1462
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Leonard Whiteman
Specialist Cert #	3712
WS Employee/Contracted	Water System Employee, or
Phone #	503-965-6636
Email Address	lwhiteman@pcjwsa.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 54</p> <p>Tested 82</p> <p>Passed 78</p> <p>Failed 4</p> <p>% of RPs tested 152%</p> <p>Comments 3 RP's were repaired and retested. 1 RP is under enforcement activity.</p>
<p>Do you have any DCs? Yes</p> <p>How many 148</p> <p>Tested 184</p> <p>Passed 178</p> <p>Failed 5</p> <p>% of DCs tested 124%</p> <p>Comments 3 DC's under enforcement activities. 2 DC's removed from system.</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system