

2025 ANNUAL SUMMARY REPORT CROSS CONNECTION & BACKFLOW PREVENTION

Water System Name & PWS ID#: PACIFIC CITY JOINT WATER - SAN AUTH, 41-00609

System Size: Large System, 300+ connections

Submitted: 03/19/26 3:43 PM

ASR Contact Information: *(if there are questions about the ASR who should we contact?)*

Name: Leonard Whiteman

Email: lwhiteman@pcjwsa.com

Phone #: +1 (503) 965-6636

Customer Base

Who does your water system serve? **Count each service connection only once**, include connections with and without a backflow assembly.

Number of **residential connections** in your water system: 1510

Number of any **high hazard connections** in your water system: 12

Number of **other types of connections** not listed above: 76

Total number of service connections: 1598

An **enabling authority** is required for all community water systems. The enabling authority allows for a water system to discontinue service for various reasons. A sample enabling authority is available for small water systems on our website: www.healthoregon.org/crossconnection. If you have not submitted an enabling authority to the State, please complete one and submit it as soon as possible.

Does your water system have an enabling authority? Yes

Was your enabling authority revised within the last year? No

This section is for LARGE SYSTEMS ONLY (Large = 300+ Service Connections)

Certified Cross Connection Specialist Information:

Name: Leonard Whiteman

Cert #: 3712

Email Address: lwhiteman@pcjwsa.com

Phone #: +1 (503) 965-6636

Does your WS have a current written backflow prevention program plan?

Yes

Does the backflow prevention plan include the following:

1. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 46 (High Hazard Table). Yes
2. Procedure for continually evaluating the degree of hazard posed by a water users premises. Yes
3. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required. Yes
4. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises. Yes
5. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements. Yes
6. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification. Yes
7. A public education program about cross connection control. Yes

Assembly Data

Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA)

Are there any RPs installed in your water system?	Yes
How many assemblies are installed in your water system?	53
How many assemblies were tested?	51
How many assemblies passed their annual test?	49
How many assemblies failed their annual test?	2
Comments:	4 RP's are under enforcement activity.

Double Check Backflow Prevention Assemblies (DC, DCVA, & DCDA)

Are there any DCs installed in your water system?	Yes
How many assemblies are installed in your water system?	140
How many assemblies were tested?	136
How many assemblies passed their annual test?	132
How many assemblies failed their annual test?	4
Comments:	6 DC's are under enforcement activity. 2 DC's were removed in 2025.

Pressure Vacuum Breaker Assemblies (PVB, PVBA, & SVBA)

Are there any PVBs installed in your water system?	No
How many assemblies are installed in your water system?	
How many assemblies were tested?	
How many assemblies passed their annual test?	
How many assemblies failed their annual test?	
Comments:	
