

## KELLER Molly A

---

**From:** Molly Keller via Smartsheet <user@smartsheet.com>  
**Sent:** Wednesday, June 3, 2020 2:41 PM  
**To:** KELLER Molly A  
**Subject:** ALDER CREEK BARLOW WATER DIST, 41-00630

**Think twice** before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



ALDER CREEK BARLOW WATER DIST, 41-00630

# 2019 Annual Summary Report (ASR)

Row 42

**Created** 03/30/20 11:14 AM

**Entered**

**Data Online**

**Water System Name** ALDER CREEK BARLOW WATER DIST, 41-00630

**ASR Contact** jeremy tower

**Email Address** nwwatersystemslc@gmail.com

**Contact Phone Number** 503-806-4734

**Residential Connections** 121

**High Hazard Connections** 0

**Other Connections** 0

**Total Connections** 121

**Enabling Authority**      Yes

---

**Revised Enabling Authority**      No

---

**CCCS Name - Large system only**      na

---

**CCCS Information - Large system only**

---

**CCCS Cert # - Large system only**

---

**CCCS Phone - Large system only**

---

**CCCS Email - Large system only**

---

**Written BFP program plan? - Large system only**

---

**BFPP - list of high hazards - Large system only**

---

**BFPP - Procedure - Large system only**

---

**BFPP Notify Water User - Large system only**

---

**BFPP - Type of Protection - Large system only**

---

**BFPP - Corrective**

**Action - Large system only**

---

**BFPP - Current records - Large system only**

---

**BFPP - Public Education - Large system only**

---

**Do you have RP?** No

---

**RP - How Many** 0

---

**RP - Tested**

---

**RP - Passed**

---

**RP - Failed**

---

**RP % Tested**

---

**RP - Comments**

---

**Do you have any DC?** Yes

---

**DC - How Many** 122

---

**DC - Tested** 122

---

**DC - Passed** 105

---

**DC - Failed** 17

---

**DC - % Tested** 100%

---

**DC - Comments** 17 out of the 122 failed the annual testing. All of those 17 devices had the failing check valves replaced or cleaned to then pass the re-test.

---

**Do you have any PVBs?** No

---

**PVB - How Many** 0

---

**PVB - Tested**

---

**PVB - Passed**

---

**PVB - Failed**

---

**PVB - % Tested**

---

**PVB -  
Comments**

---

**I certify**



---

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by [molly.a.keller@state.or.us](mailto:molly.a.keller@state.or.us)

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)