

41-00635 Sunrise Water Authority

Water System Name and PWS ID#	000635
System Size	Large System, 300+ connections
Date Report was Received	03/02/21 12:39 PM
ASR Contact	Toby A Henderson
Email Address	thenderson@sunrisewater.com
Contact Phone Number	503-683-7268
Residential Connection	16148
High Hazard Connection	444
Other Connections	2078
Total Connections	18670
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Toby A Henderson
Specialist Cert #	4296
WS Employee/Contracted	Water System Employee, or
Phone #	503-683-7268
Email Address	thenderson@sunrisewater.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 226</p> <p>Tested 226</p> <p>Passed 226</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 1452</p> <p>Tested 1452</p> <p>Passed 1400</p> <p>Failed 52</p> <p>% of DCs tested 100%</p> <p>Comments Notified to retest</p>
<p>Do you have any PVBs? Yes</p> <p>How many 5</p> <p>Tested 5</p> <p>Passed 5</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system