

2018 Annual Summary Report (ASR)

Row 258

Primary

Entered

Data Online

Water System Name PORTLAND WATER BUREAU, 41-00657

ASR Contact Dave Barrigan

Email Address Dave.Barrigan@portlandoregon.gov

Contact Phone Number 503-823-7479

Residential Connections 159073

High Hazard Connections 6783

Other Connections 33123

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name David Barrigan

CCCS Information Water System Employee, or

CCCS Cert # 627

CCCS Phone 503-823-7479

CCCS Email Dave.Barrigan@portlandoregon.gov

Current written backflow prevention program plan? Yes

BFPP - list of high hazards Yes

BFPP - Procedure Yes

BFPP Notify Water User Yes

BFPP - Type of Protection Yes

BFPP - Corrective Action Yes

BFPP - Current records Yes

BFPP - Public Education Yes

Do you have RP? Yes

RP - How Many 6783

RP - Tested 6301

RP - Passed 5922

RP - Failed 379

% Tested

RP - Comments

Do you have any DC? Yes

DC - How Many 15399

DC - Tested 14286

DC - Passed 13883

DC - Failed 403

DC - Comments

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments We do not allow PVB's to be installed as premises isolation protection.

I certify

Column47
