

Water System Name and PWS ID#	PORTLAND WATER BUREAU, 41-00657
System Size	Large System, 300+ connections
Date Report was Received	03/25/21 5:34 AM
ASR Contact	Dave Barrigan
Email Address	Dave.Barrigan@portlandoregon.gov
Contact Phone Number	503-823-8436
Residential Connection	172,724.00
High Hazard Connection	7397
Other Connections	20,618.00
Total Connections	200739
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	David Barrigan
Specialist Cert #	627
WS Employee/Contracted	Water System Employee, or
Phone #	503-823-8436
Email Address	Dave.Barrigan@portlandoregon.gov
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 7397</p> <p>Tested 6251</p> <p>Passed 5985</p> <p>Failed 266</p> <p>% of RPs tested 85%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 15,854.00</p> <p>Tested 13,374.00</p> <p>Passed 13,040.00</p> <p>Failed 334</p> <p>% of DCs tested 84%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system