

# 2018 Annual Summary Report (ASR)

Row 162

---

**Primary**

---

**Entered** 

---

**Water System Name** WEST SLOPE WATER DISTRICT, 41-00660

---

**ASR Contact** gary pline

---

**Email Address** garypline@wswd.org

---

**Contact Phone Number** 5415720200

---

**Residential Connections** 3021

---

**High Hazard Connections** 232

---

**Other Connections** 17

---

**Enabling Authority** Yes

---

**Revised Enabling Authority** No

---

**CCCS Name** gary pline

---

**CCCS Information** Water System Employee, or

---

---

<b>CCCS Cert #</b>	6663
<b>CCCS Phone</b>	5415720200
<b>CCCS Email</b>	garyline@wswd.org
<b>Current written backflow prevention program plan?</b>	Yes
<b>BFPP - list of high hazards</b>	Yes
<b>BFPP - Procedure</b>	Yes
<b>BFPP Notify Water User</b>	Yes
<b>BFPP - Type of Protection</b>	Yes
<b>BFPP - Corrective Action</b>	Yes
<b>BFPP - Current records</b>	Yes
<b>BFPP - Public Education</b>	Yes
<b>Do you have RP?</b>	Yes
<b>RP - How Many</b>	143
<b>RP - Tested</b>	134
<b>RP - Passed</b>	129

---

---

**RP - Failed**      5

---

**% Tested**

---

**RP - Comments**

---

**Do you have any DC?**      Yes

---

**DC - How Many**    783

---

**DC - Tested**        734

---

**DC - Passed**        721

---

**DC - Failed**        13

---

**DC - Comments**

---

**Do you have any PVBs?**      Yes

---

**PVB - How Many**      4

---

**PVB - Tested**        4

---

**PVB - Passed**        4

---

**PVB - Failed**        0

---

**PVB - Comments**

---

**I certify**           

---

**Column47**

---