

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Tuesday, January 28, 2020 3:52 PM
To: Molly Keller
Subject: WEST SLOPE WATER DISTRICT, 41-00660

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



WEST SLOPE WATER DISTRICT, 41-00660

2019 Annual Summary Report (ASR)

Row 63

Primary

Entered

Data Online

Water System Name WEST SLOPE WATER DISTRICT, 41-00660

ASR Contact Gary Pline

Email Address gpline@wswd.org

Contact Phone Number 503-292-2777

Residential Connections 2988

High Hazard Connections 218

Other Connections 17

Enabling Authority Yes

Revised Enabling Authority	No
CCCS Name	Gary Pline
CCCS Information	Water System Employee, or
CCCS Cert #	6663
CCCS Phone	503-292-2777
CCCS Email	gpline@wswd.org
Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	147
RP - Tested	137
RP - Passed	129
RP - Failed	8
% Tested	

**RP -
Comments**

**Do you have
any DC?** Yes

DC - How Many 815

DC - Tested 750

DC - Passed 741

DC - Failed 7

**DC -
Comments**

**Do you have
any PVBs?** Yes

**PVB - How
Many** 5

PVB - Tested 5

PVB - Passed 5

PVB - Failed 0

**PVB -
Comments**

I certify

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)