

Water System Name and PWS ID# ^{TUALATIN VALLEY WATER DISTRICT, 41-00665} System Size Large System, 300+ connections		
Date Report was Received ^{03/31/21 3:53 PM}		
ASR Contact Kahlil Howell		
Email Address Kahlil.Howell@tvwd.org		
Contact Phone Number ⁵⁰³⁻⁸⁴⁸⁻³⁰²⁹		
Residential Connection 56,947.00		
High Hazard Connection 709		
Other Connections _{2,537.00}		
Total Connections 60193		
Enabling Authority Yes		
Did you revise your Enabling Authority?No		
This section for LARGE Systems Only		
Cross Connection Specialist Kahlil Howell		
Specialist Cert # ⁵⁴⁰³		
WS Employee/Contracted Water System Employee, or		
Phone $\#^{503-848-3029}$		
Email Address Kahlil.Howell@tvwd.org		
Written Backflow Protection Program		
Written BFP program plan?		
List of high hazards Yes		
Procedure Yes		
Notify Water Users Yes		
Type of Protection Yes		
Corrective Action Yes		
Current Records Yes		
Public Education Yes		



Do you have any RPs? Yes	
How many	
Tested	1,611.00
Passed	1515
Failed	96
% of RPs tested	89%
	88% of RPBAs tested 49 of the 96 failures were resolved
Comments	Please note: 2020 ASR lists 709 High hazard connections - Counted each property with one or more RPBA as one high hazard connection. 2019 ASR lists 1,928 High Hazard connections - Counted all RPBA's as individual connections and disonnected wells were counted.
Do you have any DCs?	Yes
How many	21,355.00
Tested	20,610.00
Passed	20,328.00
Failed	282
% of DCs tested	97%
Comments	96% DCVAs tested 129 of the 282 failures were resolved
Do you have any PVBs?Yes	
How many ¹⁹¹	
Tested ¹⁷⁹	
Passed 176	
Failed ³	
% of PVBs Tested 94%	
Comments 93% PVBAs and SVBAs tested	

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system