

# 2018 Annual Summary Report (ASR)

Row 282

---

**Primary**


---

**Entered** 


---

**Data Online** 


---

**Water System Name** ROCKWOOD PUD, 41-00668
 

---

**ASR Contact** Chris Kipp
 

---

**Email Address** ckipp@rwpud.org
 

---

**Contact Phone Number** 503-674-4510
 

---

**Residential Connections** 11730
 

---

**High Hazard Connections** 166
 

---

**Other Connections** 1709
 

---

**Enabling Authority** Yes
 

---

**Revised Enabling Authority** No
 

---

**CCCS Name** Christopher Kipp
 

---

**CCCS Information** Water System Employee, or
 

---

**CCCS Cert #** 688913
 

---

**CCCS Phone** 503-674-4510
 

---

**CCCS Email** ckipp@rwpud.org
 

---

**Current written backflow prevention program plan?** Yes
 

---

<b>BFPP - list of high hazards</b>	Yes
<b>BFPP - Procedure</b>	Yes
<b>BFPP Notify Water User</b>	Yes
<b>BFPP - Type of Protection</b>	Yes
<b>BFPP - Corrective Action</b>	Yes
<b>BFPP - Current records</b>	Yes
<b>BFPP - Public Education</b>	Yes
<b>Do you have RP?</b>	Yes
<b>RP - How Many</b>	346
<b>RP - Tested</b>	352
<b>RP - Passed</b>	3
<b>RP - Failed</b>	5
<b>% Tested</b>	
<b>RP - Comments</b>	5RPBA's were repaired & there were 11 new installations.
<b>Do you have any DC?</b>	Yes
<b>DC - How Many</b>	1933
<b>DC - Tested</b>	1962
<b>DC - Passed</b>	1892
<b>DC - Failed</b>	48
<b>DC - Comments</b>	There were 22 repairs & 50 new installations
<b>Do you have any PVBs?</b>	Yes
<b>PVB - How Many</b>	38

<b>PVB - Tested</b>	40
<b>PVB - Passed</b>	36
<b>PVB - Failed</b>	2
<b>PVB - Comments</b>	2 PVBA's were repaired
<b>I certify</b>	<input checked="" type="checkbox"/>
<b>Column47</b>	