

| | |
|--|--------------------------------|
| Water System Name and PWS ID# | ROCKWOOD PUD, 41-00668 |
| System Size | Large System, 300+ connections |
| Date Report was Received | 02/24/21 7:54 AM |
| ASR Contact | Chris Kipp |
| Email Address | Ckipp@rwpud.org |
| Contact Phone Number | 503-674-4510 |
| Residential Connection | 11770 |
| High Hazard Connection | 176 |
| Other Connections | 1706 |
| Total Connections | 13652 |
| Enabling Authority | Yes |
| Did you revise your Enabling Authority? | No |
| This section for LARGE Systems Only | |
| Cross Connection Specialist | Christopher Kipp |
| Specialist Cert # | 688913 |
| WS Employee/Contracted | Water System Employee, or |
| Phone # | 5036744510 |
| Email Address | ckipp@rwpud.org |
| Written Backflow Protection Program | |
| Written BFP program plan? | Yes |
| List of high hazards | Yes |
| Procedure | Yes |
| Notify Water Users | Yes |
| Type of Protection | Yes |
| Corrective Action | Yes |
| Current Records | Yes |
| Public Education | Yes |

Do you have any RPs? Yes

How many 372

Tested 264

Passed 249

Failed 15

% of RPs tested 71%

Comments While we did meet the 70% mark, many facilities in our district did not get tested this year. We anticipate a much better numbers in 2021.

Do you have any DCs? Yes

How many 2002

Tested 1679

Passed 1667

Failed 12

% of DCs tested 84%

Comments

Do you have any PVBs? Yes

How many 38

Tested 37

Passed 37

Failed 0

% of PVBs Tested 97%

Comments

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system