

Water System Name and PWS ID#	PORT ORFORD, CITY OF, 41-00670
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 7:10 PM
ASR Contact	John Isadore
Email Address	jisadore@portorford.org
Contact Phone Number	907-654-9757
Residential Connection	752.00
High Hazard Connection	14
Other Connections	61
Total Connections	827
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Dan Anderson
Specialist Cert #	3266
WS Employee/Contracted	Contracted Service
Phone #	541-297-4119
Email Address	danderson@cityofbandon.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 14</p> <p>Tested 14</p> <p>Passed 14</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 17</p> <p>Tested 17</p> <p>Passed 16</p> <p>Failed 1</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system