



**QUESTIONS 8 - 10** are for **LARGE SYSTEMS ONLY** (Large = 300+ Service Connections) and are specific to the required **written backflow prevention program plan** outlined in [OAR 333-061-0070\(9\)\(b\)](#)

**7. Certified Cross Connection Specialist Information:**

Water system Employee       Contracted service

Name: Jacob Zeigler      Cert #: 6365

Email Address: jzeigler@cityofprineville.com      Phone #: 541-447-7844

**8. Does your WS have a current written backflow prevention program plan?**       Yes  No

**9. Does the backflow prevention plan include the following:**

a. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 42 (High Hazard Table).       Yes  No

b. Procedure for continually evaluating the degree of hazard posed by a water users premises.       Yes  No

c. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required.       Yes  No

d. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises.       Yes  No

e. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements.       Yes  No

f. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification.       Yes  No

g. A public education program about cross connection control.       Yes  No

**10. Do you have any Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA) installed in your water system?**  Yes  No  
*(if you answered yes, answer the questions below)*

a. How many assemblies are installed in your water system?      205

b. How many assemblies were tested?      192

c. How many assemblies passed their annual test?      192

d. How many assemblies failed their annual test?      13

Comments: 192 tested, as before the large data centers with major ongoing construction remove them and we are not always notified.

11. Do you have any **Double Check Backflow Prevention Assemblies** (DC, DCVA, & DCDA) installed in your water system?  Yes  No (if you answered yes, answer the questions below)

- a. How many assemblies are installed in your water system? 2120
- b. How many assemblies were tested? 2086
- c. How many assemblies passed their annual test? 2049
- d. How many assemblies failed their annual test? 37

e. Comments: Most of the homes that were not tested are vacant or bank owned. No contact

12. Do you have any **Pressure Vacuum Breaker Assemblies** (PVB, PVBA, & SVBA) installed in your water system?

Yes  No (if you answered yes, answer the questions below)

- a. How many assemblies are installed in your water system? 10
- b. How many assemblies were tested? 10
- c. How many assemblies passed their annual test? 10
- d. How many assemblies failed their annual test? 0

e. Comments: \_\_\_\_\_

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system.

Printed Name: Lori Ontko Title: Contract Administrator

Signature:  Date: 1-30-25

**Return completed reports by March 31, 2025.**

**Email:** [cross.connection@odhsoha.oregon.gov](mailto:cross.connection@odhsoha.oregon.gov), **Fax:** 971-673-0694 or

**Mail:** DWS-Cross Connection; 800 NE Oregon Street, Suite 640; Portland, OR 97293

**Questions?** [cross.connection@odhsoha.oregon.gov](mailto:cross.connection@odhsoha.oregon.gov) or 971-673-0321

To get Cross Connection notifications, go to [www.healthoregon.org/crossconnection](http://www.healthoregon.org/crossconnection) and click on the '[Sign Up for Cross Connection News](#)'