

## 2020 Cross Connection Annual Summary Report (ASR)

Water System Name and PWS ID# CITY OF RAINIER, 41-00689

System Size Large System, 300+ connections

**Date Report was Received** 03/25/21 8:17 PM

ASR Contact Brian Liga

Email Address bliga@cityofrainier

**Contact Phone Number** 503-410-9600

**Residential Connection** 848.00

High Hazard Connection 17

Other Connections 46

**Total Connections** 911

**Enabling Authority** Yes

Did you revise your Enabling Authority? No

## This section for LARGE Systems Only

Cross Connection Specialist Brian Liga

Specialist Cert #<sup>207312</sup>

WS Employee/Contracted Water System Employee, or

Phone # 503-410-9600

Email Address bliga@cityofrainier.com

## Written Backflow Protection Program

Written BFP program plan? Yes

List of high hazards Yes

Procedure Yes

Notify Water Users Yes

Type of Protection Yes

Corrective Action Yes

Current Records Yes

Public Education No



## 2020 Cross Connection Annual Summary Report (ASR)

Do you have any RPs? Yes

How many <sup>22</sup>

Tested <sup>20</sup>

Passed <sup>20</sup>

Failed<sup>0</sup>

% of RPs tested 91%

Comments The assemblies that have not been tested are scheduled to be tested next month

Do you have any DCs? Yes

How many<sup>43</sup>

Tested<sup>38</sup>

Passed<sup>38</sup>

Failed<sup>0</sup>

% of DCs tested<sup>88%</sup>

Comments The assemblies that have not been tested are scheduled to be tested next month

Do you have any PVBs?Yes

How many 1

Tested<sup>0</sup>

Passed<sup>0</sup>

Failed<sup>0</sup>

% of PVBs Tested0%

Comments Just found this assembly recently and it is scheduled to be tested

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system