

2018 Annual Summary Report (ASR)

Row 117

Primary

Entered **Data Online** **Water System Name** GOBLE WATER ASSOCIATION, 41-00690**ASR Contact** Devin Geiger**Email Address** devin@hilandwater.com**Contact Phone Number** 503-554-8333**Residential Connections** 26**High Hazard Connections** 0**Other Connections** 1**Enabling Authority** Yes**Revised Enabling Authority** No**CCCS Name****CCCS Information****CCCS Cert #****CCCS Phone****CCCS Email**

Current written backflow prevention program plan?

BFPP - list of high hazards

BFPP - Procedure

BFPP Notify Water User

BFPP - Type of Protection

BFPP - Corrective Action

BFPP - Current records

BFPP - Public Education

Do you have RP? Yes

RP - How Many 1

RP - Tested

RP - Passed

RP - Failed

% Tested 0%

RP - Comments

Do you have any DC? No

DC - How Many

DC - Tested

DC - Passed

DC - Failed

DC - Comments

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
