

2018 Annual Summary Report (ASR)

Row 267

Primary**Entered****Data Online****Water System Name**

REDMOND WATER DEPARTMENT, 41-00693

ASR Contact

Joshua Wyma

Email Address

jwyma75@gmail.com

Contact Phone Number

541-504-2019

Residential Connections

9495

High Hazard Connections

320

Other Connections

1187

Enabling Authority

Yes

Revised Enabling Authority

No

CCCS Name

Joshua Wyma

CCCS Information

Water System Employee, or

CCCS Cert #

4528

CCCS Phone

541-504-2019

CCCS Email

jwyma75@gmail.com

Current written backflow prevention program plan?

Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	345
RP - Tested	345
RP - Passed	334
RP - Failed	11
% Tested	100%
RP - Comments	Failures were repaired or replaced
Do you have any DC?	Yes
DC - How Many	7796
DC - Tested	7662
DC - Passed	7155
DC - Failed	204
DC - Comments	Failures were repaired or replaced
Do you have any PVBs?	Yes
PVB - How Many	2

PVB - Tested	1
PVB - Passed	1
PVB - Failed	0
PVB - Comments	
I certify	☒
Column47	