

| | |
|--|--------------------------------|
| Water System Name and PWS ID# | REEDSPORT, CITY OF, 41-00699 |
| System Size | Large System, 300+ connections |
| Date Report was Received | 03/30/21 12:54 PM |
| ASR Contact | Jeff Blum |
| Email Address | jblum@cityofreedsport.org |
| Contact Phone Number | 541-662-2055 |
| Residential Connection | 1,729.00 |
| High Hazard Connection | 14 |
| Other Connections | 246 |
| Total Connections | 1989 |
| Enabling Authority | Yes |
| Did you revise your Enabling Authority? | No |
| This section for LARGE Systems Only | |
| Cross Connection Specialist | Jeff Blum |
| Specialist Cert # | 3729 |
| WS Employee/Contracted | Water System Employee, or |
| Phone # | 541-662-2055 |
| Email Address | jblum@cityofreedsport.org |
| Written Backflow Protection Program | |
| Written BFP program plan? | Yes |
| List of high hazards | Yes |
| Procedure | Yes |
| Notify Water Users | Yes |
| Type of Protection | Yes |
| Corrective Action | Yes |
| Current Records | Yes |
| Public Education | No |

| |
|---|
| <p>Do you have any RPs? Yes</p> <p>How many 74</p> <p>Tested 67</p> <p>Passed 57</p> <p>Failed 8</p> <p>% of RPs tested 91%</p> <p>Comments</p> |
| <p>Do you have any DCs? Yes</p> <p>How many 64</p> <p>Tested 52</p> <p>Passed 46</p> <p>Failed 6</p> <p>% of DCs tested 81%</p> <p>Comments</p> |
| <p>Do you have any PVBs? Yes</p> <p>How many 1</p> <p>Tested 1</p> <p>Passed 1</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p> |

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system