

Water System Name and PWS ID#	RIDDLE, CITY OF, 41-00706
System Size	Large System, 300+ connections
Date Report was Received	03/16/21 4:15 PM
ASR Contact	ROBERT TILTON
Email Address	corpwrt@frontier.com
Contact Phone Number	541-874-2905
Residential Connection	441.00
High Hazard Connection	17
Other Connections	87
Total Connections	545
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	ROBERT TILTON
Specialist Cert #	3222
WS Employee/Contracted	Water System Employee, or
Phone #	541-874-2905
Email Address	corpwrt@frontier.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 32</p> <p>Tested 25</p> <p>Passed 24</p> <p>Failed 1</p> <p>% of RPs tested 78%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 17</p> <p>Tested 15</p> <p>Passed 15</p> <p>Failed 0</p> <p>% of DCs tested 88%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system