

Updated

Public Health Division

Drinking Water Services



**2024 ANNUAL SUMMARY REPORT
CROSS CONNECTION & BACKFLOW PREVENTION**

Received
May 1 2025
Cross Connection

Please fill out the Annual Summary Report accurately and completely with **data from 2024**. Keep a completed copy for your records.

PLEASE ANSWER ALL QUESTIONS. INCOMPLETE REPORTS WILL DELAY PROCESSING.

Submit completed reports by March 31, 2025

Email: cross.connection@odhsoha.oregon.gov, Fax: 971-673-0694

Mail: DWS-Cross Connection; 800 NE Oregon Street, Suite 640; Portland, OR 97293

1. **Water System Name:** City of Rogue River **PWS ID#** 41-00712

2. **What size is your water system?**

☐ Small (1-299 connections) ☒ Large (300+ connections)

3. **ASR Contact Information:** *(if there are questions about the ASR who should we contact?)*

Name: Debbie Bunker

Email: dbunker@cityofrogueriver.org Phone #: 541-499-8041

4. **Customer Base:** Who does your water system serve? Count each service connection only once, include connections with and without a backflow assembly.

a. Do you have any residential connections in your water system?

☒ Yes ☐ No How many: 665

b. Do you have any high hazard connections in your water system?

☒ Yes ☐ No How many: 54

c. Do you have any other types of connections not listed above?

☒ Yes ☐ No How many: 134

Comments: We have been updating our utility billing system to more accurately reflect the classification of connections.

5. **Does your water system have an enabling authority?** ☒ Yes ☐ No (see note above)

6. **Was your enabling authority revised within the last year?**

☐ Yes, email a copy to cross.connection@odhsoha.oregon.gov ☒ No

QUESTIONS 8 - 10 are for **LARGE SYSTEMS ONLY** (Large = 300+ Service Connections) and are specific to the required **written backflow prevention program plan** outlined in OAR 333-061-0070(9)(b)

7. Certified Cross Connection Specialist Information:

☒ Water system Employee ☐ Contracted service

Name: Deborah Bunker Cert #: 895731

Email Address: dbunker@cityofrogueriver.org Phone #: 541-499-8041

8. Does your WS have a current written backflow prevention program plan? ☒ Yes ☐ No

9. Does the backflow prevention plan include the following:

a. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 46 (High Hazard Table). ☐ Yes ☐ No

b. Procedure for continually evaluating the degree of hazard posed by a water users premises. ☐ Yes ☐ No

c. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required. ☐ Yes ☐ No

d. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises. ☐ Yes ☐ No

e. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements. ☐ Yes ☐ No

f. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification. ☐ Yes ☐ No

g. A public education program about cross connection control. ☐ Yes ☐ No

10. Do you have any **Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA) installed in your water system?** ☒ Yes ☐ No

(if you answered yes, answer the questions below)

a. How many assemblies are installed in your water system? 69

b. How many assemblies were tested? 49

c. How many assemblies passed their annual test? 49

d. How many assemblies failed their annual test? 0

Comments: _____

11. Do you have any **Double Check Backflow Prevention Assemblies** (DC, DCVA, & DCDA) installed in your water system? ☒ Yes ☐ No (if you answered yes, answer the questions below)

- a. How many assemblies are installed in your water system? 305
- b. How many assemblies were tested? 230
- c. How many assemblies passed their annual test? 225
- d. How many assemblies failed their annual test? 5
- e. Comments: Letters have been sent out requiring repair or replacement of failed assemblies


12. Do you have any **Pressure Vacuum Breaker Assemblies** (PVB, PVBA, & SVBA) installed in your water system?

☐ Yes ☒ No (if you answered yes, answer the questions below)

- a. How many assemblies are installed in your water system? _____
- b. How many assemblies were tested? _____
- c. How many assemblies passed their annual test? _____
- d. How many assemblies failed their annual test? _____
- e. Comments: _____

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system.

Printed Name: Debbie Bunker **Title:** Asst. PW Director

Signature:  **Date:** 5.1.25

Return completed reports by March 31, 2025.

Email: cross.connection@odhsoha.oregon.gov, **Fax:** 971-673-0694 or

Mail: DWS-Cross Connection; 800 NE Oregon Street, Suite 640; Portland, OR 97293

Questions? cross.connection@odhsoha.oregon.gov or 971-673-0321

To get Cross Connection notifications, go to www.healthoregon.org/crossconnection and click on the '**Sign Up for Cross Connection News**'

2024 ANNUAL SUMMARY REPORT CROSS CONNECTION & BACKFLOW PREVENTION**Water System Name & PWS ID#:** ROGUE RIVER, CITY OF, 41-00712**System Size:** Large System, 300+ connections**Submitted:** 03/31/25 3:17 PM**ASR Contact Information:** *(if there are questions about the ASR who should we contact?)***Name:** Deborah Bunker**Email:** dbunker@cityofrogueriver.org**Phone #:** +1 (541) 499-8041**Customer Base**

Who does your water system serve? **Count each service connection only once**, include connections with and without a backflow assembly.

Number of **residential connections** in your water system: 665Number of any **high hazard connections** in your water system: 54Number of **other types of connections** not listed above: 134**Total number of service connections:**

An **enabling authority** is required for all community water systems. The enabling authority allows for a water system to discontinue service for various reasons. A sample enabling authority is available for small water systems on our website: www.healthoregon.org/crossconnection. If you have not submitted an enabling authority to the State, please complete one and submit it as soon as possible.

Does your water system have an enabling authority? Yes**Was your enabling authority revised within the last year?** No**This section is for LARGE SYSTEMS ONLY** (Large = 300+ Service Connections)**Certified Cross Connection Specialist Information:****Name:** Deborah Bunker**Cert #:** 895731**Email Address:** dbunker@cityofrogueriver.org**Phone #:** +1 (541) 499-8041**Does your WS have a current written backflow prevention program plan?** Yes**Does the backflow prevention plan include the following:**

- | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| 1. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 46 (High Hazard Table). | <u>Yes</u> |
| 2. Procedure for continually evaluating the degree of hazard posed by a water users premises. | <u>Yes</u> |
| 3. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required. | <u>Yes</u> |
| 4. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises. | <u>Yes</u> |
| 5. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements. | <u>Yes</u> |
| 6. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification. | <u>Yes</u> |
| 7. A public education program about cross connection control. | <u>No</u> |

Assembly Data

Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA)

Are there any RPs installed in your water system? Yes

How many assemblies are installed in your water system? 68

How many assemblies were tested? 47

How many assemblies passed their annual test? 47

How many assemblies failed their annual test? 0

Comments: I am double checking with the historic testers to see if we are missing any reports and will submit an amended report if appropriate. The City has gone through significant staff changes recently and I did not see these were missing.

Double Check Backflow Prevention Assemblies (DC, DCVA, & DCDA)

Are there any DCs installed in your water system? Yes

How many assemblies are installed in your water system? 305

How many assemblies were tested? 219

How many assemblies passed their annual test? 216

How many assemblies failed their annual test? 3

Comments: Letters have been sent out requiring repair or replacement of failed assemblies

Pressure Vacuum Breaker Assemblies (PVB, PVBA, & SVBA)

Are there any PVBs installed in your water system? No

How many assemblies are installed in your water system?

How many assemblies were tested?

How many assemblies passed their annual test?

How many assemblies failed their annual test?

Comments:
