

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Thursday, March 26, 2020 1:44 PM
To: Molly Keller
Subject: UMPQUA RANCH COOP, 41-00714

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



UMPQUA RANCH COOP, 41-00714

2019 Annual Summary Report (ASR)

Row 24

Created 03/23/20 1:58 PM

Entered

Data Online

Water System Name UMPQUA RANCH COOP, 41-00714

ASR Contact Jonathan Woody

Email Address john@oecadmin.com

Contact Phone Number 541-643-6137

Residential Connections 110

High Hazard Connections 0

Other Connections 2

Enabling Authority Yes

**Revised
Enabling
Authority** No

**CCCS Name -
Large system
only** na

**CCCS
Information -
Large system
only**

**CCCS Cert # -
Large system
only**

**CCCS Phone -
Large system
only**

**CCCS Email -
Large system
only**

**Written BFP
program plan?
- Large system
only**

**BFPP - list of
high hazards -
Large system
only**

**BFPP -
Procedure -
Large system
only**

**BFPP Notify
Water User -
Large system
only**

**BFPP - Type of
Protection -
Large system
only**

**BFPP -
Corrective
Action - Large
system only**

BFPP - Current records - Large system only

BFPP - Public Education - Large system only

Do you have RP? No

RP - How Many 2

RP - Tested 2

RP - Passed 2

RP - Failed 0

RP % Tested 100%

RP - Comments

Do you have any DC? Yes

DC - How Many 1

DC - Tested 1

DC - Passed 1

DC - Failed 0

DC - % Tested 100%

DC - Comments

Do you have any PVBs? No

PVB - How Many 0

PVB - Tested

PVB - Passed

PVB - Failed

PVB - % Tested

**PVB -
Comments**

This system was recently contracted by our company to work through an list of deficiencies. We have not been able to survey the distribution system to determine the exact number of backflow devices, but I believe each home has a double check that has not been included on this report in the past. The board has been notified that an inventory needs to be done and these devices will need tested this year. This report will be updated next year once this work has been completed.

I certify



[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)