

Water System Name and PWS ID#	ROBERTS CREEK WATER DISTRICT, 41-00717
System Size	Large System, 300+ connections
Date Report was Received	02/24/21 2:41 PM
ASR Contact	STACEY WERNER
Email Address	office@rcwaterdistrict.com
Contact Phone Number	541-679-6451
Residential Connection	2960
High Hazard Connection	78
Other Connections	2
Total Connections	3040
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	DANIEL RADFORD
Specialist Cert #	2413
WS Employee/Contracted	Water System Employee, or
Phone #	5417845610
Email Address	crew@rcwaterdistrict.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

Do you have any RPs? Yes
 How many 115
 Tested 116
 Passed 88
 Failed 14
 % of RPs tested 101%
 Comments

Do you have any DCs? Yes
 How many 1323
 Tested 1348
 Passed 1127
 Failed 40
 % of DCs tested 102%
 Comments

Do you have any PVBs? Yes
 How many 2
 Tested 2
 Passed 2
 Failed 0
 % of PVBs Tested 100%
 Comments

I certify the information provided is true
 to the best of my knowledge. Providing ^{true}
 false information may result in penalties
 to the individual and to the water system