

2024 ANNUAL SUMMARY REPORT CROSS CONNECTION & BACKFLOW PREVENTION**Water System Name & PWS ID#:** HILAND WC - BOULDER CREEK, 41-00722**System Size:** Small System, 1-299 connections**Submitted:** 04/28/25 10:23 AM**ASR Contact Information:** *(if there are questions about the ASR who should we contact?)***Name:** Curtis Olson**Email:** jperryman@nwnaturalwaterservices.com**Phone #:** +1 (503) 554-8333**Customer Base**

Who does your water system serve? **Count each service connection only once**, include connections with and without a backflow assembly.

Number of **residential connections** in your water system: 131Number of any **high hazard connections** in your water system: 0Number of **other types of connections** not listed above: 0**Total number of service connections:** 131

An **enabling authority** is required for all community water systems. The enabling authority allows for a water system to discontinue service for various reasons. A sample enabling authority is available for small water systems on our website: www.healthoregon.org/crossconnection. If you have not submitted an enabling authority to the State, please complete one and submit it as soon as possible.

Does your water system have an enabling authority? Yes**Was your enabling authority revised within the last year?** No**This section is for LARGE SYSTEMS ONLY** (Large = 300+ Service Connections)**Certified Cross Connection Specialist Information:****Name:** _____ **Cert #:** _____**Email Address:** _____ **Phone #:** _____**Does your WS have a current written backflow prevention program plan?** _____**Does the backflow prevention plan include the following:**

1. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 46 (High Hazard Table). _____
2. Procedure for continually evaluating the degree of hazard posed by a water users premises. _____
3. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required. _____
4. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises. _____
5. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements. _____
6. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification. _____
7. A public education program about cross connection control. _____

Assembly Data

Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA)

| | |
|---------------------------------------------------------|---------------------------------|
| Are there any RPs installed in your water system? | Yes |
| How many assemblies are installed in your water system? | 1 |
| How many assemblies were tested? | 0 |
| How many assemblies passed their annual test? | 0 |
| How many assemblies failed their annual test? | 0 |
| Comments: | This BF was not tested in error |

Double Check Backflow Prevention Assemblies (DC, DCVA, & DCDA)

| | |
|---------------------------------------------------------|----|
| Are there any DCs installed in your water system? | No |
| How many assemblies are installed in your water system? | |
| How many assemblies were tested? | |
| How many assemblies passed their annual test? | |
| How many assemblies failed their annual test? | |
| Comments: | |

Pressure Vacuum Breaker Assemblies (PVB, PVBA, & SVBA)

| | |
|---------------------------------------------------------|----|
| Are there any PVBs installed in your water system? | No |
| How many assemblies are installed in your water system? | |
| How many assemblies were tested? | |
| How many assemblies passed their annual test? | |
| How many assemblies failed their annual test? | |
| Comments: | |
