## **KELLER Molly A**


From: Molly Keller via Smartsheet <user@smartsheet.com>

Sent: Tuesday, January 28, 2020 3:52 PM

**To:** Molly Keller

**Subject:** ST HELENS, CITY OF, 41-00724

**Think twice** before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



Revised Enabling Authority	No
CCCS Name	David Elder
CCCS Information	Water System Employee, or
CCCS Cert #	3493
CCCS Phone	503-397-3532
CCCS Email	davee@ci.st-helens.or.us
Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	120
RP - Tested	120
RP - Passed	115
RP - Failed	5
% Tested	

RP - Comments	All failed devices were repaired and retested and passed.
Do you have any DC?	Yes
DC - How Many	435
DC - Tested	435
DC - Passed	430
DC - Failed	5
DC - Comments	All failed devices were repaired and retested and passed.
Do you have any PVBs?	Yes
PVB - How Many	4
PVB - Tested	4
PVB - Passed	4
PVB - Failed	0
PVB - Comments	
I certify	
View in Smartsheet	

Sent using <u>Smartsheet</u> - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by <u>molly.a.keller@state.or.us</u>
© 2020 Smartsheet Inc. | <u>Contact</u> | <u>Privacy Policy</u> | <u>User Agreement</u> | <u>Report Abuse/Spam</u>