

Water System Name and PWS ID#	ST HELENS, CITY OF, 41-00724
System Size	Large System, 300+ connections
Date Report was Received	01/15/21 9:08 AM
ASR Contact	Sheri Ingram
Email Address	sherii@ci.st-helens.or.us
Contact Phone Number	503-397-3532
Residential Connection	4643
High Hazard Connection	82
Other Connections	198
Total Connections	4923
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	David Elder
Specialist Cert #	3493
WS Employee/Contracted	Water System Employee, or
Phone #	503-397-3532
Email Address	davee@ci.st-helens.or.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 122</p> <p>Tested 122</p> <p>Passed 120</p> <p>Failed 2</p> <p>% of RPs tested 100%</p> <p>Comments Failed devised were repaired and re-tested and passed</p>
<p>Do you have any DCs? Yes</p> <p>How many 475</p> <p>Tested 475</p> <p>Passed 472</p> <p>Failed 3</p> <p>% of DCs tested 100%</p> <p>Comments Failed devised were repaired and re-tested and passed</p>
<p>Do you have any PVBs? Yes</p> <p>How many 4</p> <p>Tested 4</p> <p>Passed 4</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system