

Water System Name and PWS ID#	KEIZER, CITY OF, 41-00744
System Size	Large System, 300+ connections
Date Report was Received	02/23/21 2:04 PM
ASR Contact	Brandon Buchheit
Email Address	Buchheitb@keizer.org
Contact Phone Number	503-856-3547
Residential Connection	9895
High Hazard Connection	113
Other Connections	702
Total Connections	10710
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Brandon Buchheit
Specialist Cert #	5876
WS Employee/Contracted	Water System Employee, or
Phone #	5038563547
Email Address	Buchheitb@keizer.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 285</p> <p>Tested 284</p> <p>Passed 272</p> <p>Failed 12</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 3123</p> <p>Tested 3077</p> <p>Passed 3011</p> <p>Failed 66</p> <p>% of DCs tested 99%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 23</p> <p>Tested 22</p> <p>Passed 21</p> <p>Failed 1</p> <p>% of PVBs Tested 96%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system