KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>

Sent: Wednesday, June 3, 2020 2:51 PM

To: KELLER Molly A

Subject: ORCHARD HEIGHTS WATER ASSN, 41-00783

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



Enabling Authority	Yes
Revised Enabling Authority	No
CCCS Name - Large system only	na
CCCS Information - Large system only	
CCCS Cert # - Large system only	
CCCS Phone - Large system only	
CCCS Email - Large system only	
Written BFP program plan? - Large system only	
BFPP - list of high hazards - Large system only	
BFPP - Procedure - Large system only	
BFPP Notify Water User - Large system only	
BFPP - Type of Protection - Large system only	
BFPP - Corrective	

Action - Large system only	
BFPP - Current records - Large system only	
BFPP - Public Education - Large system only	
Do you have RP?	Yes
RP - How Many	2
RP - Tested	2
RP - Passed	2
RP - Failed	0
RP % Tested	100%
RP - Comments	
Do you have any DC?	Yes
DC - How Many	152
DC - Tested	152
DC - Passed	150
DC - Failed	2
DC - % Tested	100%
DC - Comments	The two devices that failed were repaired and passed the test after repaired.
Do you have any PVBs?	No
PVB - How Many	0
PVB - Tested	
PVB - Passed	

PVB - % Tested PVB - Comments	PVB -	PVB - Failed			
PVB - Comments	PVB - Comments	PVB - % Test	æd		
	i certify				

Sent using <u>Smartsheet</u> - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us
© 2020 Smartsheet Inc. | <u>Contact</u> | <u>Privacy Policy</u> | <u>User Agreement</u> | <u>Report Abuse/Spam</u>