

Water System Name and PWS ID#	SCAPPOOSE, CITY OF, 41-00792
System Size	Large System, 300+ connections
Date Report was Received	03/24/21 10:50 AM
ASR Contact	Kathleen Head
Email Address	khead@cityofscappoose.org
Contact Phone Number	503-543-7146 ext 221
Residential Connection	2,621.00
High Hazard Connection	25
Other Connections	93
Total Connections	2739
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Doug Nassimbene
Specialist Cert #	5080
WS Employee/Contracted	Water System Employee, or
Phone #	503-543-8404
Email Address	dnassimbene@cityofscappoose.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 74</p> <p>Tested 65</p> <p>Passed 63</p> <p>Failed 2</p> <p>% of RPs tested 88%</p> <p>Comments Getting familiar with a new backflow assembly testing compliance software.</p>
<p>Do you have any DCs? Yes</p> <p>How many 743</p> <p>Tested 632</p> <p>Passed 632</p> <p>Failed 1</p> <p>% of DCs tested 85%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 3</p> <p>Tested 3</p> <p>Passed 3</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system