

Water System Name and PWS ID#	SEAL ROCK WATER DISTRICT, 41-00798
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 11:12 AM
ASR Contact	Bradley/Seal Rock Water District Wynn
Email Address	bwynn@srwd.org
Contact Phone Number	541-961-7558
Residential Connection	2,561.00
High Hazard Connection	3
Other Connections	52
Total Connections	2616
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	BRadley Wynn
Specialist Cert #	4677
WS Employee/Contracted	Water System Employee, or
Phone #	541-961-7558
Email Address	bwynn@srwd.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes

How many 8

Tested 6

Passed 6

Failed 1

% of RPs tested 75%

Comments We had one that was tested late, and it did pass in 2021. The one that failed was replaced with a new device in 2021.

Do you have any DCs? Yes

How many 37

Tested 37

Passed 35

Failed 2

% of DCs tested 100%

Comments

Do you have any PVBs? Yes

How many 1

Tested 1

Passed 1

Failed 0

% of PVBs Tested 100%

Comments

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system