

<b>Water System Name and PWS ID#</b>	SHERIDAN, CITY OF, 41-00811
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	02/24/21 9:23 AM
<b>ASR Contact</b>	Ken Hamilton
<b>Email Address</b>	kenh@sheridanpw.com
<b>Contact Phone Number</b>	503-560-7447
<b>Residential Connection</b>	1441
<b>High Hazard Connection</b>	10
<b>Other Connections</b>	107
<b>Total Connections</b>	1558
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Ken Hamilton
<b>Specialist Cert #</b>	5841
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	5034370674
<b>Email Address</b>	kenh@sheridanpw.com
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	No

<p>Do you have any RPs? Yes</p> <p>How many 35</p> <p>Tested 28</p> <p>Passed 24</p> <p>Failed 3</p> <p>% of RPs tested 80%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 564</p> <p>Tested 322</p> <p>Passed 316</p> <p>Failed 5</p> <p>% of DCs tested 57%</p> <p>Comments Covid 19 and changing of personal led to less being tested.</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true  
to the best of my knowledge. Providing  
false information may result in penalties  
to the individual and to the water system