

# 2018 Annual Summary Report (ASR)

Row 301

---

**Primary**


---

**Entered** 


---

**Data Online** 


---

**Water System Name** SILVERTON, CITY OF, 41-00823
 

---

**ASR Contact** Chelsea Starner
 

---

**Email Address** cstarner@silverton.or.us
 

---

**Contact Phone Number** 503-874-2281
 

---

**Residential Connections** 2068
 

---

**High Hazard Connections** 59
 

---

**Other Connections** 331
 

---

**Enabling Authority** Yes
 

---

**Revised Enabling Authority** No
 

---

**CCCS Name** Travis Sperle
 

---

**CCCS Information** Water System Employee, or
 

---

**CCCS Cert #** 3022
 

---

**CCCS Phone** 503-874-2280
 

---

**CCCS Email** tsperle@silverton.or.us
 

---

**Current written backflow prevention program plan?** Yes
 

---

<b>BFPP - list of high hazards</b>	Yes
<b>BFPP - Procedure</b>	Yes
<b>BFPP Notify Water User</b>	Yes
<b>BFPP - Type of Protection</b>	Yes
<b>BFPP - Corrective Action</b>	Yes
<b>BFPP - Current records</b>	Yes
<b>BFPP - Public Education</b>	Yes
<b>Do you have RP?</b>	Yes
<b>RP - How Many</b>	107
<b>RP - Tested</b>	107
<b>RP - Passed</b>	102
<b>RP - Failed</b>	5
<b>% Tested</b>	100%
<b>RP - Comments</b>	All failures were repaired and passed subsequent test, or were replaced.
<b>Do you have any DC?</b>	Yes
<b>DC - How Many</b>	937
<b>DC - Tested</b>	930
<b>DC - Passed</b>	913
<b>DC - Failed</b>	17
<b>DC - Comments</b>	Seven devices not tested due to construction projects with no connection of device to water. All failures were repaired and passed subsequent test, or were replaced.
<b>Do you have any PVBs?</b>	Yes

<b>PVB - How Many</b>	3
<b>PVB - Tested</b>	3
<b>PVB - Passed</b>	3
<b>PVB - Failed</b>	0
<b>PVB - Comments</b>	n/a
<b>I certify</b>	<input checked="" type="checkbox"/>
<b>Column47</b>	