

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Wednesday, January 22, 2020 2:50 PM
To: Molly Keller
Subject: SILVERTON, CITY OF, 41-00823

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



SILVERTON, CITY OF, 41-00823

2019 Annual Summary Report (ASR)

Row 34

Primary

Entered

Data Online

Water System Name SILVERTON, CITY OF, 41-00823

ASR Contact Chelsea Starner

Email Address cstarner@silverton.or.us

Contact Phone Number 5038742206

Residential Connections 3116

High Hazard Connections 62

Other Connections 349

Enabling Authority Yes

Revised Enabling Authority	No
CCCS Name	Chelsea Starner
CCCS Information	Water System Employee, or
CCCS Cert #	380573
CCCS Phone	5038742206
CCCS Email	cstarner@silverton.or.us
Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	110
RP - Tested	92
RP - Passed	76
RP - Failed	16
% Tested	

RP - Comments	All failures were retested and passed.
Do you have any DC?	Yes
DC - How Many	975
DC - Tested	864
DC - Passed	806
DC - Failed	58
DC - Comments	No related comments to submit.
Do you have any PVBs?	Yes
PVB - How Many	5
PVB - Tested	4
PVB - Passed	4
PVB - Failed	0
PVB - Comments	No related comments to submit.
I certify	<input checked="" type="checkbox"/>
View in Smartsheet	

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)