

|  |                                |
|--|--------------------------------|
| <b>Water System Name and PWS ID#</b>           | SILVERTON, CITY OF, 41-00823   |
| <b>System Size</b>                             | Large System, 300+ connections |
| <b>Date Report was Received</b>                | 01/07/21 8:32 AM               |
| <b>ASR Contact</b>                             | Chelsea Starnier               |
| <b>Email Address</b>                           | cstarnier@silvertton.or.us     |
| <b>Contact Phone Number</b>                    | 503-874-2206                   |
| <b>Residential Connection</b>                  | 3201                           |
| <b>High Hazard Connection</b>                  | 65                             |
| <b>Other Connections</b>                       | 351                            |
| <b>Total Connections</b>                       | 3617                           |
| <b>Enabling Authority</b>                      | Yes                            |
| <b>Did you revise your Enabling Authority?</b> | No                             |
| <b>This section for LARGE Systems Only</b>     |                                |
| <b>Cross Connection Specialist</b>             | Chelsea Starnier               |
| <b>Specialist Cert #</b>                       | 380573                         |
| <b>WS Employee/Contracted</b>                  | Water System Employee, or      |
| <b>Phone #</b>                                 | 503-874-2206                   |
| <b>Email Address</b>                           | cstarnier@silvertton.or.us     |
| <b>Written Backflow Protection Program</b>     |                                |
| <b>Written BFP program plan?</b>               | Yes                            |
| <b>List of high hazards</b>                    | Yes                            |
| <b>Procedure</b>                               | Yes                            |
| <b>Notify Water Users</b>                      | Yes                            |
| <b>Type of Protection</b>                      | Yes                            |
| <b>Corrective Action</b>                       | Yes                            |
| <b>Current Records</b>                         | Yes                            |
| <b>Public Education</b>                        | Yes                            |

|  |
|--|
| <p>Do you have any RPs? Yes</p> <p>How many 115</p> <p>Tested 115</p> <p>Passed 101</p> <p>Failed 14</p> <p>% of RPs tested 100%</p> <p>Comments n/a</p> |
| <p>Do you have any DCs? Yes</p> <p>How many 1031</p> <p>Tested 999</p> <p>Passed 934</p> <p>Failed 65</p> <p>% of DCs tested 97%</p> <p>Comments n/a</p> |
| <p>Do you have any PVBs? Yes</p> <p>How many 5</p> <p>Tested 5</p> <p>Passed 5</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments n/a</p>      |

I certify the information provided is true  
to the best of my knowledge. Providing  
false information may result in penalties  
to the individual and to the water system