

Water System Name and PWS ID#	RAINBOW WATER DISTRICT, 41-00839
System Size	Large System, 300+ connections
Date Report was Received	03/15/21 10:53 AM
ASR Contact	Jodi Sanders
Email Address	jodi@rwdonline.net
Contact Phone Number	541-746-1676
Residential Connection	2,395.00
High Hazard Connection	1
Other Connections	4
Total Connections	2400
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Eric Carlson
Specialist Cert #	5541
WS Employee/Contracted	Water System Employee, or
Phone #	541-746-1676
Email Address	eric@rwdonline.net
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes

How many 21

Tested 21

Passed 21

Failed 0

% of RPs tested 100%

Comments Last year I entered the number of RP assemblies incorrectly. I should have entered that we had 19 last year and instead I entered 119.

Do you have any DCs? Yes

How many 187

Tested 187

Passed 185

Failed 2

% of DCs tested 100%

Comments

Do you have any PVBs? Yes

How many 130

Tested 130

Passed 129

Failed 1

% of PVBs Tested 100%

Comments

I certify the information provided is true
to the best of my knowledge. Providing ^{true}
false information may result in penalties
to the individual and to the water system