

Water System Name and PWS ID#	STANFIELD, CITY OF, 41-00842
System Size	Large System, 300+ connections
Date Report was Received	02/22/21 3:05 PM
ASR Contact	Scott Arthur Morris
Email Address	smorris@cityofstanfield.com
Contact Phone Number	541-561-8292
Residential Connection	720
High Hazard Connection	6
Other Connections	17
Total Connections	743
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	scott morris
Specialist Cert #	3058
WS Employee/Contracted	Water System Employee, or
Phone #	5415618292
Email Address	smorris@cityofstanfield.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

<p>Do you have any RPs? Yes</p> <p>How many 13</p> <p>Tested 12</p> <p>Passed 12</p> <p>Failed 0</p> <p>% of RPs tested 92%</p> <p>Comments I have one assembly that has not been put into service yet.</p>
<p>Do you have any DCs? Yes</p> <p>How many 115</p> <p>Tested 97</p> <p>Passed 95</p> <p>Failed 2</p> <p>% of DCs tested 84%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 5</p> <p>Tested 4</p> <p>Passed 4</p> <p>Failed 0</p> <p>% of PVBs Tested 80%</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system