

| | |
|--|---|
| Water System Name and PWS ID# | SUNRIVER WATER LLC/SUNRIVER UTILITIES, 41-00846 |
| System Size | Large System, 300+ connections |
| Date Report was Received | 01/08/21 7:23 AM |
| ASR Contact | Spencer Mitchell |
| Email Address | smitchell@sunriverutilities.com |
| Contact Phone Number | 541-593-4197 |
| Residential Connection | 3540 |
| High Hazard Connection | 89 |
| Other Connections | 1234 |
| Total Connections | 4863 |
| Enabling Authority | Yes |
| Did you revise your Enabling Authority? | No |
| This section for LARGE Systems Only | |
| Cross Connection Specialist | Spencer Mitchell |
| Specialist Cert # | 5537 |
| WS Employee/Contracted | Water System Employee, or |
| Phone # | 541-593-4197 |
| Email Address | smitchell@sunriverutilities.com |
| Written Backflow Protection Program | |
| Written BFP program plan? | Yes |
| List of high hazards | Yes |
| Procedure | Yes |
| Notify Water Users | Yes |
| Type of Protection | Yes |
| Corrective Action | Yes |
| Current Records | Yes |
| Public Education | Yes |

Do you have any RPs? Yes

How many 81

Tested 56

Passed 53

Failed 3

% of RPs tested 69%

Comments Most of our RP's are on Commercial connections and Due to COVID it was extremely difficult to access these businesses. Some were/are closed.

Do you have any DCs? Yes

How many 2073

Tested 1876

Passed 1772

Failed 104

% of DCs tested 90%

Comments

Do you have any PVBs? Yes

How many 1

Tested 0

Passed 0

Failed 0

% of PVBs Tested 0%

Comments This PVB is on an irrigation system and is an opt out of our cc program. The owner did not have the device tested by a third party and subsequently did not give us a passing report. Due to COVID concerns for the owners this device did not get tested.

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system