

| Water System Name and PWS ID# SUTHERLIN, CITY OF, 41-00847 |
|--|
| System Size Large System, 300+ connections |
| Date Report was Received ^{03/25/21 10:03 AM} |
| ASR Contact Shawn L McHaffie |
| Email Address s.mchaffie@ci.sutherlin.or.us |
| Contact Phone Number ⁵⁴¹⁻⁴⁵⁹⁻³⁵⁴² |
| Residential Connection 2,683.00 |
| High Hazard Connection 180 |
| Other Connections ₀ |
| Total Connections 2863 |
| Enabling Authority Yes |
| Did you revise your Enabling Authority? Yes, attach the revised copy below |
| This section for LARGE Systems Only |
| Cross Connection Specialist Shawn McHaffie |
| Specialist Cert # ⁵⁶¹⁷⁸⁷ |
| WS Employee/Contracted ^{Water System Employee, or} |
| Phone $\#^{541-459-3542}$ |
| Email Address s.mchaffie@ci.sutherlin.or.us |
| Written Backflow Protection Program |
| Written BFP program plan? |
| List of high hazards ^{Yes} |
| Procedure Yes |
| Notify Water Users Yes |
| Type of Protection Yes |
| Corrective Action ^{Yes} |
| Current Records Yes |
| Public Education Yes |
| |



| Do you have any RPs? Yes | |
|-------------------------------------|--|
| How many ²⁰² | |
| Tested ¹⁸⁴ | |
| Passed ¹⁸⁰ | |
| Failed ¹ | |
| % of RPs tested ^{91%} | |
| Comments 3 failed | initial testing , with retest/repair 1 failed final |
| Do you have any DCs? ^{Yes} | |
| How many ⁹⁶⁹ | |
| Tested ⁷³⁸ | |
| Passed ⁶⁷⁹ | |
| Failed ¹ | |
| % of DCs tested ^{76%} | |
| Comments 27 failed | initial testing, after repairs/retest 1 failed final testing |
| Do you have any PVBs?Yes | |
| How many ¹ | |
| Tested ¹ | |
| Passed ¹ | |
| Failed ⁰ | |
| % of PVBs Tested 100% | |
| Comments | |
| Comments | |

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system