

2025 ANNUAL SUMMARY REPORT CROSS CONNECTION & BACKFLOW PREVENTION

Water System Name & PWS ID#: TALENT, CITY OF, 41-00857

System Size: Large System, 300+ connections

Submitted: 03/26/26 2:40 PM

ASR Contact Information: *(if there are questions about the ASR who should we contact?)*

Name: Jared Wolfe

Email: jwolfe@cityoftalent.org

Phone #: +1 (541) 210-1531

Customer Base

Who does your water system serve? **Count each service connection only once**, include connections with and without a backflow assembly.

Number of **residential connections** in your water system: 2024

Number of any **high hazard connections** in your water system: 15

Number of **other types of connections** not listed above: 137

Total number of service connections: 2176

An **enabling authority** is required for all community water systems. The enabling authority allows for a water system to discontinue service for various reasons. A sample enabling authority is available for small water systems on our website: www.healthoregon.org/crossconnection. If you have not submitted an enabling authority to the State, please complete one and submit it as soon as possible.

Does your water system have an enabling authority? Yes

Was your enabling authority revised within the last year? No

This section is for LARGE SYSTEMS ONLY (Large = 300+ Service Connections)

Certified Cross Connection Specialist Information:

Name: Jared Wolfe

Cert #: 659137

Email Address: jwolfe@cityoftalent.org

Phone #: +1 (541) 210-1531

Does your WS have a current written backflow prevention program plan?

Yes

Does the backflow prevention plan include the following:

1. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 46 (High Hazard Table).

Yes

2. Procedure for continually evaluating the degree of hazard posed by a water users premises.

Yes

3. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required.

Yes

4. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises.

Yes

5. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements.

Yes

6. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification.

Yes

7. A public education program about cross connection control.

No

Assembly Data

Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA)

Are there any RPs installed in your water system?	Yes
How many assemblies are installed in your water system?	242
How many assemblies were tested?	227
How many assemblies passed their annual test?	227
How many assemblies failed their annual test?	0

Comments: A correction was found for the 2024 ASR, the correct count for 2024 RPs is 233 installed 222 tested, 222 passed and 0 failed.

Due to the Alameda Fire some homes are still being rebuilt. Only backflow devices not destroyed in the fire and newly installed assemblies have been tested.

Double Check Backflow Prevention Assemblies (DC, DCVA, & DCDA)

Are there any DCs installed in your water system?	Yes
How many assemblies are installed in your water system?	964
How many assemblies were tested?	883
How many assemblies passed their annual test?	883
How many assemblies failed their annual test?	0

Comments: A correction was found for the 2024 ASR, the correct count for 2024 DCs is 964 installed 890 tested, 890 passed and 0 failed.

Due to the Alameda Fire some homes are still being rebuilt. Only backflow devices not destroyed in the fire and newly installed assemblies have been tested.

Pressure Vacuum Breaker Assemblies (PVB, PVBA, & SVBA)

Are there any PVBs installed in your water system?	Yes
How many assemblies are installed in your water system?	3
How many assemblies were tested?	2
How many assemblies passed their annual test?	2
How many assemblies failed their annual test?	0

Comments: Due to the Alameda Fire some homes are still being rebuilt. Only backflow devices not destroyed in the fire and newly installed assemblies have been tested.