

2018 Annual Summary Report (ASR)

Row 60

Primary

Entered **Data Online** **Water System Name** CIRCLE C IMPROVEMENT DISTRICT, 41-00861**ASR Contact** Randi Ruddell**Email Address** naterandi@hotmail.com**Contact Phone Number** 541-504-7951**Residential Connections** 72**High Hazard Connections** 0**Other Connections** 3**Enabling Authority** Yes**Revised Enabling Authority** Yes, please attach the revised copy below**CCCS Name****CCCS Information****CCCS Cert #****CCCS Phone****CCCS Email**

Current written backflow prevention program plan?

BFPP - list of high hazards

BFPP - Procedure

BFPP Notify Water User

BFPP - Type of Protection

BFPP - Corrective Action

BFPP - Current records

BFPP - Public Education

Do you have RP? No

RP - How Many

RP - Tested

RP - Passed

RP - Failed

% Tested #DIVIDE BY ZERO

RP - Comments

Do you have any DC? Yes

DC - How Many 71

DC - Tested 71

DC - Passed 24

DC - Failed 47

DC - Comments We had a very high failure rate this year. Our backflow devices are roughly 18 years old. Our maintenance supervisor and DRC Robert Eastham is in the process of getting certified to test & repair backflow devices through the state & we plan to have them all passing (either repaired or replaced) by 3/31/2019.

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
