

2018 Annual Summary Report (ASR)

Row 75

Primary

Entered

Data Online

Water System Name CROOKED RIVER RANCH WTR CO, 41-00862

ASR Contact Frank Day

Email Address frank@crrwater.com

Contact Phone Number 541-923-1041

Residential Connections 1614

High Hazard Connections 1

Other Connections 0

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name frank day

CCCS Information Water System Employee, or

CCCS Cert # 5709

CCCS Phone 541-279-0058

CCCS Email frank@crrwater.com

Current written backflow prevention program plan?

Yes

BFPP - list of high hazards

Yes

BFPP - Procedure

Yes

BFPP Notify Water User

Yes

BFPP - Type of Protection

Yes

BFPP - Corrective Action

Yes

BFPP - Current records

Yes

BFPP - Public Education

Yes

Do you have RP?

Yes

RP - How Many

1

RP - Tested

1

RP - Passed

1

RP - Failed

% Tested

100%

RP - Comments

Do you have any DC?

Yes

DC - How Many

1426

DC - Tested

1419

DC - Passed

1419

DC - Failed

DC - Comments The 7 DCs that were not tested are vacant properties with no water service during 2018. Our policy is to immediately test the assembly one the water is restored.

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
