

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Wednesday, January 22, 2020 2:44 PM
To: Molly Keller
Subject: CROOKED RIVER RANCH WTR CO, 41-00862

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



CROOKED RIVER RANCH WTR CO, 41-00862

2019 Annual Summary Report (ASR)

Row 6

Primary

Entered

Data Online

Water System Name CROOKED RIVER RANCH WTR CO, 41-00862

ASR Contact Frank Day

Email Address frank@crwater.com

Contact Phone Number 5419231041

Residential Connections 1591

High Hazard Connections 1

Other Connections 41

Enabling Authority Yes

**Revised
Enabling
Authority** No

CCCS Name Frank Day

**CCCS
Information** Water System Employee, or

CCCS Cert # 5709

CCCS Phone 5412790058

CCCS Email frank@crrwater.com

**Current written
backflow
prevention
program plan?** Yes

**BFPP - list of
high hazards** Yes

**BFPP -
Procedure** Yes

**BFPP Notify
Water User** Yes

**BFPP - Type of
Protection** Yes

**BFPP -
Corrective
Action** Yes

**BFPP - Current
records** Yes

**BFPP - Public
Education** Yes

**Do you have
RP?** Yes

RP - How Many 1

RP - Tested 1

RP - Passed 1

RP - Failed 0

% Tested

**RP -
Comments**

**Do you have
any DC?** Yes

DC - How Many 1573

DC - Tested 1570

DC - Passed 1570

DC - Failed 0

**DC -
Comments** 3 DCVA has the water turned off and is not in use.

**Do you have
any PVBs?** No

**PVB - How
Many**

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)