

Water System Name and PWS ID#	CHENOWITH PUD, 41-00867
System Size	Large System, 300+ connections
Date Report was Received	03/26/21 1:22 PM
ASR Contact	Brenton Adams
Email Address	brentona@chenowithwater.com
Contact Phone Number	541-296-5363
Residential Connection	1,348.00
High Hazard Connection	4
Other Connections	89
Total Connections	1441
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Brenton Adams
Specialist Cert #	6299
WS Employee/Contracted	Water System Employee, or
Phone #	541-296-5363
Email Address	brentona@chenowithwater.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 48</p> <p>Tested 44</p> <p>Passed 44</p> <p>Failed 4</p> <p>% of RPs tested 92%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 140</p> <p>Tested 136</p> <p>Passed 131</p> <p>Failed 5</p> <p>% of DCs tested 97%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 22</p> <p>Tested 22</p> <p>Passed 20</p> <p>Failed 2</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system