

2018 Annual Summary Report (ASR)

Row 330

Primary

Entered

Data Online

Water System Name THE DALLES, CITY OF, 41-00869

ASR Contact K.C. Ferres

Email Address kferres@ci.the-dalles.or.us

Contact Phone Number 541-296-5401 x2013

Residential Connections 4010

High Hazard Connections 200

Other Connections 672

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name K.C. Ferres

CCCS Information Water System Employee, or

CCCS Cert # 5768

CCCS Phone 541-296-5401 x2013

CCCS Email kferres@ci.the-dalles.or.us

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	324
RP - Tested	324
RP - Passed	324
RP - Failed	12
% Tested	
RP - Comments	12 failures repaired and retested, 4 removed, 10 reduced pressure assemblies installed.
Do you have any DC?	Yes
DC - How Many	1306
DC - Tested	1296
DC - Passed	1295
DC - Failed	41
DC - Comments	40 failed, repaired and tested. one double check not repaired at this time. 35 new installed. 9 double checks not tested.
Do you have any PVBs?	Yes
PVB - How	140

Many

PVB - Tested 139

PVB - Passed 139

PVB - Failed 9

PVB - Comments 1 PVB installed. 9 PVB failed ,repaired and retested.

I certify

Column47
