

Water System Name and PWS ID#	THE DALLES, CITY OF, 41-00869
System Size	Large System, 300+ connections
Date Report was Received	03/08/21 1:28 PM
ASR Contact	K.C. Ferres
Email Address	kferres@ci.the-dalles.or.us
Contact Phone Number	541-296-5401 ext 2013
Residential Connection	4,048.00
High Hazard Connection	208
Other Connections	706
Total Connections	4962
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	K.C. Ferres
Specialist Cert #	5768
WS Employee/Contracted	Water System Employee, or
Phone #	541-296-5401 ext. 2013
Email Address	kferres@ci.the-dalles.or.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
 How many 324
 Tested 322
 Passed 281
 Failed 43
 % of RPs tested 99%
 Comments 4 new reduced pressure assemblies installed. 5 assemblies removed. 43 failed and repaired. 2 assemblies not tested one shut off.

Do you have any DCs? Yes
 How many 1414
 Tested 1333
 Passed 1280
 Failed 53
 % of DCs tested 94%
 Comments 36 new Double checks installed. 3 removed. 53 failed and 49 repaired and one shut off. 28 not tested.

Do you have any PVBs? Yes
 How many 144
 Tested 142
 Passed 142
 Failed 8
 % of PVBs Tested 99%
 Comments 1 pvb not tested. one removed .

I certify the information provided is true
 to the best of my knowledge. Providing true
 false information may result in penalties
 to the individual and to the water system