

Water System Name and PWS ID#	FAIRVIEW WATER DISTRICT, 41-00887
System Size	Large System, 300+ connections
Date Report was Received	03/21/21 9:09 PM
ASR Contact	David Pace
Email Address	davidpace@fairviewwater.com
Contact Phone Number	503-842-4333
Residential Connection	628.00
High Hazard Connection	29
Other Connections	49
Total Connections	706
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	David Pace
Specialist Cert #	4505
WS Employee/Contracted	Water System Employee, or
Phone #	503-842-4333
Email Address	davidpace@fairviewwater.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

Do you have any RPs? Yes
How many 35
Tested 33
Passed 32
Failed 1
% of RPs tested 94%
Comments

Do you have any DCs? Yes
How many 28
Tested 27
Passed 27
Failed 0
% of DCs tested 96%
Comments

Do you have any PVBs? No
How many 0
Tested
Passed
Failed
% of PVBs Tested
Comments

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system