

Water System Name and PWS ID#	JUNO NON-PROFIT WATER CO, 41-00889
System Size	Small System, 1-299 connections
Date Report was Received	02/25/21 2:01 PM
ASR Contact	Nonda Zwald
Email Address	nonda@zwald.org
Contact Phone Number	503-842-1515
Residential Connection	59
High Hazard Connection	0
Other Connections	1
Total Connections	60
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	na
Specialist Cert #	
WS Employee/Contracted	
Phone #	
Email Address	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards	
Procedure	
Notify Water Users	
Type of Protection	
Corrective Action	
Current Records	
Public Education	

<p>Do you have any RPs? No</p> <p>How many⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of RPs tested</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many¹</p> <p>Tested¹</p> <p>Passed¹</p> <p>Failed⁰</p> <p>% of DCs tested^{100%}</p> <p>Comments We have a farmer that had a small 1" RP on his line. When he upgraded his line to a 2" the plumber installed a DC. It needs to be an RP. The farmer is continuing to try and get the plumber back out to switch out the double check and replace it with an RP.</p>
<p>Do you have any PVBs? No</p> <p>How many⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system